

出國報告(出國類別：國外承攬)

關島 CABRAS 電廠#1 機汽機大修

服務機關：台灣電力公司電力修護處

姓名職稱：曾琨程 工程專員

派赴國家：美國 關島

出國期間：106/07/14~106/09/16

報告日期：106年9月18日

行政院及所屬各機關出國報告提要

出國報告名稱：

關島 CABRAS 電廠#1 機汽機大修 頁數 77 含附件：是 否

出國計畫主辦機關/聯絡人/電話

台灣電力公司電力修護處/曾琨程/02-27853199-258

出國人員姓名/服務機關/單位/職稱/電話

曾琨程/台灣電力公司/電力修護處/第一工作隊專員/02-27853199-258

出國類別：1 考察 2 進修 3 研究 4 實習 5 其他

出國期間：106/07/14~106/09/16

出國地區：美國關島

報告日期：106/09/18

分類號/目

關鍵詞：

內容摘要：(二百至三百字)

關島 cabras 電廠#1 機汽機大修預定工期 35 天於 2017 年 7 月 17 日開始大修至 8 月 18 日。大修主要工作內容為全開蓋大修包含高低壓開蓋大修與汽機主閥拆解大修工作。

轉子吊出後，經由 NDT 檢查，確認並無任何葉片受損需更換，另汽機主閥全部拆卸檢修。MSV 嚮導閥 SEAT 與 RSV DISC 在經過 NDT 檢查後發現有裂痕(線性指示)，此次大修將 MSV 嚮導閥 SEAT 與 RSV DISC 更換成新品。此外因 CV#1 在拆解過程中無法將 STEM 從閥體中取下，所以將其切割取下後更換成新品(STEM 與 DISC)。

在動葉與靜葉檢查，並未發現葉片或葉根有裂縫需更換。僅有中壓第十一級上下半靜葉環與中壓第十級靜葉環下半葉片有些吹蝕現象，經過焊補磨修與 PT 檢查後，將其回裝。汽機汽封更換方面，本次檢查發現只有 HP7 之 Packing ring 有些微變形，將其更換為新品。因應電廠要求，低壓外缸安全膜片也做了更換。因電廠輔機系統與飼水泵在大修後啟動有些問題，第一次並聯時間為 8/28 19:42，發電量為 0.4MW。

本文電子檔已傳至出國報告資訊網 (<http://open.nat.gov.tw/reportwork>)

2017 關島 CABRAS # 1 STEAM TURBINE 大修報告

台灣電力股份有限公司

電力修護處



台灣電力公司

Taiwan power company

目錄

I：前言	第 1 頁
II：工作內容	第 3 頁
III：檢修表單	第 39 頁
IV：建議事項	第 77 頁

I：前言

關島 cabras 電廠#1 機汽機大修預定工期 35 天於 2017 年 7 月 17 日開始大修至 8 月 18 日。大修主要工作內容為全開蓋大修包含高低壓開蓋大修與汽機主閥拆解大修工作。

轉子吊出後，經由 NDT 檢查，確認並無任何葉片受損需更換，另汽機主閥全部拆卸檢修。MSV 嚮導閥 SEAT 與 RSV DISC 在經過 NDT 檢查後發現有裂痕(線性指示)，此次大修將 MSV 嚮導閥 SEAT 與 RSV DISC 更換成新品。此外因 CV#1 在拆解過程中無法將 STEM 從閥體中取下，所以將其切割取下後更換成新品(STEM 與 DISC)。

在動葉與靜葉檢查，並未發現葉片或葉根有裂縫需更換。僅有中壓第十一級上下半靜葉環與中壓第十級靜葉環下半葉片有些吹蝕現象，經過焊補磨修與 PT 檢查後，將其回裝。汽機汽封更換方面，本次檢查發現只有 HP7 之 Packing ring 有些微變形，將其更換為新品。因應電廠要求，低壓外缸安全膜片也做了更換。因電廠輔機系統與飼水泵在大修後啟動有些問題，第一次並聯時間為 8/28 19:42，發電量為 0.4MW。

大修工期：

預定工期：07/17/2017 to 09/18/2017

完工日期：07/17/2017 to 09/12/2017

汽機配重與超速跳脫試驗

08/27/2017. Start to Roll turbine, speed up to 900 rpm

08/28/2017 19:42. Turbine is synchronized

09/09/2017, add 336gm(6 pieces) balance piece on 240°~250°,

09/14/2017, decrease 56gm(1 pieces) balance piece on 250°

Then restart turbine to rate speed

09/11/2017 12:14 Output 24.8MW

震動數值如下： unit:mils

24.8MW	1X	1Y	2X	2Y	3X	3Y	4X	4Y	5X	5Y
12:14	0.6	0.6	3.1	2.6	1.9	1.2	1.4	0.5	0.6	0.5

軸承金屬溫度如下：

Bearing	1	2	3	4	5	Thrust Inactive (TE)	Thrust Active (GE)
T. F°	183.2	163.6	145.9	160.3	103.1	119.9	143.9
T. C°	84	73.1	63.3	71.3	39.5	48.8	62.2

09/11/2017 14:42 Output 41.4MW

震動數值如下： unit:mils

41.4MW	1X	1Y	2X	2Y	3X	3Y	4X	4Y	5X	5Y
14:42	0.6	0.6	2.9	1.9	2.1	1.3	1.2	0.6	0.7	0.4

軸承金屬溫度如下：

Bearing	1	2	3	4	5	Thrust Inactive (TE)	Thrust Active (GE)
T. F°	184.2	164.1	146.5	160.5	105.4	120.9	150.1
T. C°	84.5	73.4	63.6	71.4	40.8	29.4	65.6

09/15/2017 19:17 Output 16.1MW

震動數值如下： unit:mils

16.1MW	1X	1Y	2X	2Y	3X	3Y	4X	4Y	5X	5Y
19:17	0.5	0.4	2.7	2.2	2.1	1.2	1.1	0.6	0.8	0.6

II：工作內容





依據合約檢修內容有下列幾項工作：







1：汽缸

1.1：拆除高低壓外缸與內缸，檢查動靜葉片軸徑向間隙、更換汽封與清除保溫

汽輪機外觀(TE Side)	汽輪機外觀(GEN Side)
	
外罩拆除	保溫拆除
	
拆除跨管	拆除跨管
	

<p>跨管拆除</p>	<p>跨管法蘭拆除</p>
	
<p>低壓人孔拆除</p>	<p>低壓內導流板拆除</p>
	
<p>低壓外缸拆除</p>	<p>低壓外缸吊掛</p>
	

<p>低壓內缸螺栓拆除</p>	<p>低壓內缸螺栓拆除</p>
	
<p>低壓內缸拆除吊掛</p>	<p>低壓轉子動葉片</p>
	
<p>#2 BRG 油槽外殼</p>	<p>#3 BRG 油槽拆除</p>
	
<p>高壓進汽管法蘭拆除</p>	<p>高壓進汽管法蘭拆除</p>
	

<p>高壓外缸拆除</p>	<p>高壓外缸頂升作業</p>
	
<p>高壓外缸頂升作業</p>	<p>高壓外缸頂升作業</p>
	
<p>高壓外缸頂升作業</p>	<p>高壓外缸頂升作業</p>
	
<p>高壓外缸吊掛作業</p>	<p>高壓內缸</p>
	

中壓上半靜葉環



中壓上半靜葉吊掛











高壓內缸拆解吊掛



高壓內缸拆解吊掛



<p>#3 BRG 上半油槽蓋拆解</p>	<p>聯軸器蓋拆解</p>
	
<p>聯軸器螺栓拆解</p>	<p>#2 BRG 上半拆解</p>
	
<p>#3 BRG 上半拆解</p>	<p>推力軸承拆解</p>
	
<p>轉子吊離前間隙核測</p>	<p>轉子吊掛作業</p>
	

轉子置於架上




上半靜葉拆解吊出



HP7 汽封更換

















HP7 汽封更換




2. Rotor, Discs and blades. the following parts shall be inspected.

2.1 Saddle or stand for the rotor and nondestructive testing

低壓段動葉片 MT check	高中壓段動葉片 MT check
	
#1 軸頸 PT	#1 軸頸 PT
	
#2 軸頸 PT	#2 軸頸 PT
	

<p>#3 軸頸 PT</p>	<p>#3 軸頸 PT</p>
	
<p>動葉片葉根檢查</p>	<p>Shrouds inspect</p>
	
<p>配重塊相對位置確認</p>	<p>動葉片葉根 MT 檢查</p>
	
<p>動葉片與護環間隙核測</p>	<p>打鉚處硬度檢查</p>
	

2.2 Run out check within the 0.002"





UNIT : 1/100mm

	A	B	C
1	NA	19	22
2	NA	20	23
3	NA	23	22
4	NA	22	22
5	NA	22	22
6	NA	22	23
7	NA	22	22
8	NA	20	21

3 : Nozzle block and buckets

3.1 IP 11(toper and lower half) and IP10 (lower half) nozzle van found some erosion and need to repair., the other nozzle van are good.






3.2 Perform MT&PT&UT

靜葉片導軌 MT check	靜葉片導軌 MT check
	
螺栓 UT check	靜葉片 MT check
	





4 : Bearings and journals


4.1 : Clean and check contact surface or scrape if necessary.

#1 BRG 與軸頸接觸面試驗	#2BRG 與軸頸接觸面試驗
	


#3BRG 與軸頸接觸面試驗	
	

4.2 : Perform PT&UT.


#1 軸頸 PT	#1 軸頸 PT
	
#2 軸頸 PT	#2 軸頸 PT
	




4.3 : Perform center line check and adjustment.




4.4 : Repaire Babbitt if needed or replace it with new parts.





4.5 : Check inactive thrust bearing









5 : Main steam control valves(GVx6、MSVx1、RSVx1、IVx1、Steam seal regulator valve、Blow down valve, and 5 extraction steam non-return valves.)




5.1 : Disassemble the valve

<p>CV 彈簧拆除</p>	<p>CV 連桿拆除</p>
	
<p>CV 主閥吊掛</p>	<p>CV 主閥拆解</p>
	







<p>CV 細部拆解</p>	<p>閥桿切除作業</p>
	
<p>新閥桿 PT check</p>	<p>使用液態氮將 DISC 與閥桿組裝</p>
	
<p>將 PIN 組裝</p>	<p>閥桿新品</p>
	

<p>CV 分解後磨修</p>	<p>CV 分解後磨修</p>
	
<p>CV 驅動閥吊掛</p>	<p>CV 驅動感拆除</p>
	
<p>CV 驅動桿</p>	<p>IV 拆除吊掛</p>
	


<p>RSV SEAT</p>	<p>RSV 閥桿中心校準</p>
	
<p>RSV 拆除</p>	<p>RSV disc & stem</p>
	
<p>RSV GASKET</p>	<p>RSV&IV 閥座</p>
	

<p>RSV Disc 拆解</p>	<p>RSV 拆解</p>
	
<p>oCombine Reheat Valve (CRV) 濾網拆解</p>	<p>MSV 閥蓋</p>
	
<p>MSV 拆解</p>	<p>MSV 組裝</p>
	

5.2 : Inspect the valve body for crack by PT and Check valve disc and seat contact ; erosion and check for foreign materials

CV 閥座 PT check	CV 閥座 PT check
	
CV 閥座 PT check	CV 閥座 PT check
	
CV disc 與閥桿 PT check	CV disc 與閥桿 PT check
	

CV 連桿 PT check



CV 連桿 PT check



MSV pilot valve seat PT



MSV pilot valve seat Disc PT

















MSV pilot valve seat Disc PT











MSV pilot valve Disc PT


















<p>MSV pilot valve 閥座 PT</p>	<p>MSV pilot valve 閥座 PT</p>
	
<p>RSV 閥座 PT CHECK</p>	<p>RSV 閥座 PT CHECK</p>
	
<p>IV PT CHECK</p>	<p>IV PT CHECK</p>
	
<p>IV DISC PT CHECK</p>	<p>IV&RSV 閥座 PT CHECK</p>
	

<p>Check Valve Disc PT check</p>	<p>Check Valve Disc PT check</p>
	
<p>Check Valve 閥座 PT check</p>	<p>Check Valve 閥座 PT check</p>
	
<p>Check Valve 閥座 PT check</p>	<p>Check Valve 閥座 PT check</p>
	


5.3 : Reassemble upon completion of said work.

#1 CV 閥座 Blue Check	#1 CV Disc Blue Check
	
#3 CV 閥座 Blue Check	#3 CV Disc Blue Check
	
#5 CV 閥座 Blue Check	#5CV Disc Blue Check
	
#6 CV 閥座 Blue Check	#6CV Disc Blue Check
	

MSV 閥座 PT CHECK	Disc PT CHEKC
	
RSV 閥座 PT CHECK	RSV Disc PT CHEKC
	
IV 閥座 PT CHECK	IV Disc PT CHEKC
	
#1 Check Valve Disc Blue Check	#1 Check Valve 閥座 Blue Check
	


#2 Check Valve Disc Blue Check	#2 Check Valve 閥座 Blue Check
	
#3 Check Valve Disc Blue Check	#3 Check Valve 閥座 Blue Check
	
#4 Check Valve Disc Blue Check	#4 Check Valve 閥座 Blue Check
	
#5 Check Valve Disc Blue Check	#5 Check Valve 閥座 Blue Check
	

5.4 : Check rotor alignment、bearing center line and perform adjustment as Required






1 : TB-GEN alignment



Unit:mm



Face	T	B	L	R
0°	19.77	19.75	19.70	19.73
90°	19.72	19.76	19.74	19.70
180°	19.33	19.32	19.31	19.32
270°	19.80	19.78	19.78	19.80
Ave	19.65	19.65	19.63	19.64







Designed Value







The design data is that the offset is zero and the generator is 0.53mm low to the turbine. A mounted on the generator reading to the turbine, and with parallel gage to measure all face.

5.5 : Clean, check and inspect turning gear.









<p>慢車齒輪 PT check</p>	<p>慢車齒輪 Gear PT check</p>
	
<p>慢車傳動系統</p>	<p>慢車傳動系統</p>
	

6. Lube Oil System

6.1 : Drain and clean the oil reservoir and inspect the inside condition


<p>潤滑油槽清理</p>	<p>潤滑油槽清理</p>
	
	

6.2 : Disassemble and inspect AC & DC pump

<p>拆除 AC & DC pump</p>	<p>拆除 AC & DC pump</p>
	
<p>拆除 AC & DC pump</p>	<p>拆除 AC & DC pump</p>
	
<p>分解 AC & DC pump</p>	<p>分解 AC & DC pump</p>
	
	







AC、DC&EOP pump

		A	clearance	B	clearance	C	clearance
Wear ring(top)	Inside DIA	79.61	0.46	79.57	0.48	79.44	0.33
	Outside DIA	79.15		79.08		79.11	
Wear ring(lower)	Inside DIA	73.38	0.55	73.34	0.51	73.36	0.54
	Outside DIA	72.83		72.83		72.82	
Bushing (lower)	Inside DIA	44.58	0.15	44.61	0.17	44.60	0.16
	Outside DIA	44.43		44.44		44.44	





		STEM RUN OUT CHECK			
		0°	90°	180°	270°(0°)
A	a	0	-1	0	2
	b	0	0	0	0
	c	0	-4	0	0
B	a	0	8	13	4
	b	0	0	0	0
	c	0	1	3	1
C	a	0	6	3	-3
	b	0	0	0	0
	c	0	2	2	0

6.3 : Clean the oil cooler by brushing tubes (LUBE & EH system)

<p>分解潤滑油 cooler cover</p>	<p>分解潤滑油 the LUBE cooler cover</p>
	
<p>使用毛刷清理冷卻管(潤滑油系統)</p>	<p>使用毛刷清理冷卻管(潤滑油系統)</p>
	
<p>使用毛刷清理冷卻管 (EH System)</p>	<p>使用毛刷清理冷卻管 (EH System)</p>
	


6.4 : Flushing the piping of lube oil system

<p>油洗濾網裝設</p>	<p>油洗濾網裝設</p>
	

7 : Perform coupling alignment.



8 : Perform the necessary reinstallation and restoration



高壓外缸回裝



高壓外缸回裝



高壓螺栓回裝熱鎖



低壓外缸回裝



跨管回裝



HP inlet pipe assembly



9：汽機配重與超速跳脫試驗

08/27/2017. Start to Roll turbine, speed up to 900 rpm

08/28/2017 19:42. Turbine is synchronized

09/09/2017, add 336gm(6 pieces) balance piece on 240°~250°,

09/14/2017, decrease 56gm(1 pieces) balance piece on 250°

Then restart turbine to rate speed

09/11/2017 12:14 Output 24.8MW

震動數值如下： unit:mils

24.8MW	1X	1Y	2X	2Y	3X	3Y	4X	4Y	5X	5Y
12:14	0.6	0.6	3.1	2.6	1.9	1.2	1.4	0.5	0.6	0.5

軸承金屬溫度如下：

Bearing	1	2	3	4	5	Thrust Inactive (TE)	Thrust Active (GE)
T.F°	183.2	163.6	145.9	160.3	103.1	119.9	143.9
T.C°	84	73.1	63.3	71.3	39.5	48.8	62.2

09/11/2017 14:42 Output 41.4MW

震動數值如下： unit:mils

41.4MW	1X	1Y	2X	2Y	3X	3Y	4X	4Y	5X	5Y
14:42	0.6	0.6	2.9	1.9	2.1	1.3	1.2	0.6	0.7	0.4

軸承金屬溫度如下：

Bearing	1	2	3	4	5	Thrust Inactive (TE)	Thrust Active (GE)
T.F°	184.2	164.1	146.5	160.5	105.4	120.9	150.1
T.C°	84.5	73.4	63.6	71.4	40.8	29.4	65.6

09/15/2017 19:17 Output 16.1MW

震動數值如下： unit:mils

16.1MW	1X	1Y	2X	2Y	3X	3Y	4X	4Y	5X	5Y
19:17	0.5	0.4	2.7	2.2	2.1	1.2	1.1	0.6	0.8	0.6


III : Inspection Form

Brg Pinch Check

Cabras Plant : Unit 1 As Found Date : 21/July/2017

No.1brg mode

Unit : mm



NO.1軸承型式

NO.2、3號軸承型式


Brg NO	SIM Width	Mea Point		FUSE Thick	PINCH	DESIGN	Note
		TE	GE				
1		TOP	TE	0.39	0.08	0.05-	
			GE	0.40	0.08	0.125	
2	×0.7 =	LEFT	TE	0.40	0.08	0.05-	
			GE	0.40	0.08	0.125	
		RIGHT	TE	0.44	0.9	0.05-	
			GE	0.44	0.9	0.125	
3	×0.7 =	LEFT	TE	0.44	0.8	0.05-	
			GE	0.44	0.9	0.125	
		RIGHT	TE	0.51	0.8	0.05-	
			GE	0.51	0.8	0.125	

inspection result		qualified	verify	customer	captain
		unqualified			
		only for reference			
Option					
	redo				
	repair				
	new part replacement				
	trace				
	as it stands				


Brg Pinch Check

Cabras Plant : Unit 1 . As Left

Date : 02/Aug/2017.



No. .1brg mode



↑ No. .2&3brg mode


unit : mm

Brg NO	SIM Width	Mea Point		FUSE Thick	PINCH	DESIGN	Note
1		TOP	TE	0.80	0.08	0.00-	
			GE	0.80	0.08	0.05	
2	×0.7 =	LEFT	TE	0.80	0.08	0.00-	
			GE	0.80	0.08	0.15	
		RIGHT	TE	0.80	0.9	0.00-	
			GE	0.80	0.9	0.15	
3	×0.7 =	LEFT	TE	0.80	0.8	0.00-	
			GE	0.80	0.9	0.15	
		RIGHT	TE	0.80	0.8	0.00-	
			GE	0.80	0.8	0.05	

inspection		qualified		
		unqualified		
	result	only for reference		
Option				
	redo	verify	customer	captain
	repair			
	new part replacement			
	trace			
	as it stands			

#1、2、3Brg Clearance&Parallel Check

Cabras Plant : Unit 1 . .As Found & Left Date : 21/July/2017
02/Aug/2017.



Brg parallel check (as found) unit : mm

	A		B		C		D	
	left	right	left	right	left	right	left	right
NO.1	0.13	0.10	0.12	0.10	0.12	0.10	0.12	0.15
NO.2	0.30	0.42	0.28	0.38	0.30	0.28	0.31	0.30
NO.3	0.11	0.20	0.27	0.25	0.32	0.20	0.14	0.11

Brg parallel check (as left) unit : mm

	A		B		C		D	
	left	right	left	right	left	right	left	right
NO.1	0.13	0.10	0.12	0.10	0.12	0.10	0.12	0.15
NO.2	0.30	0.42	0.28	0.38	0.30	0.28	0.31	0.30
NO.3	0.11	0.20	0.27	0.25	0.32	0.20	0.14	0.11


brg top clearance unit : mm

	#1		#2		#3	
	TE	GE	TE	GE	TE	GE
As found	0.35	0.35	0.52	0.53	0.54	0.58
As left	0.35	035	0.52	0.53	0.54	0.58

inspection		qualified		
		unqualified		
	result	only for reference		
Option				
	redo	verify	customer	captain
	repair			
	new part replacement			
	trace			
	as it stands			

HP Rotor Axial Clearance


Cabras Plant : Unit 2 ..As Found Date : 22/July/2017.



		design HP-LH				HP-RH			
		A	B	E	F	A	B	E	F
1	design		2.99	NA		2.99	2.99	NA	
	actual	4.0	NA	NA	10.8	3.7	NA	NA	11.7
2	design	2.59	2.59	NA	5.51	2.59	2.59	NA	5.51
	actual	4.0	NA	NA	10.3	3.9	NA	NA	10.6
3	design	2.62	2.49	NA	6.60	2.62	2.49	NA	6.60
	actual	3.1	9.3	NA	10.3	3.3	9.8	NA	9.8
4	design	2.57	2.44	NA	5.00	2.57	2.44	NA	5.00
	actual	2.9	9.0	NA	11.0	3.3	9.3	NA	10.7
5	design	2.44	2.31	NA	4.95	2.44	2.31	NA	4.95
	actual	3.0	9.5	NA	10.3	3.2	9.5	NA	9.7
6	design	2.39	2.13	NA	4.88	2.39	2.13	NA	4.88
	actual	3.3	7.7	NA	16.0	3.2	7.6	NA	16.1
7	design	2.11	1.85	NA	4.72	2.11	1.85	NA	4.72
	actual	3.4	7.4	NA	13.6	3.4	7.7	NA	13.4
8	design	1.95	1.70	NA	4.57	1.95	1.70	NA	4.57
	actual	4.0	9.7	NA	9.4	4.2	9.8	NA	9.4
9	design	1.75	1.50	NA	4.45	1.75	1.50	NA	4.45
	actual	3.8	9.7	NA	11.3	3.9	9.4	NA	11.2
inspection		qualified							
result		unqualified							
		only for reference							
Option									
	redo			verify		customer		captain	
	repair								
	new part replacement								
	trace								
	as it stands								

HP Rotor Axial Clearance


Cabras Plant : Unit 2 ..As Left Date : 02/Aug/2017.



		HP-LH				HP-RH			
		A	B	E	F	A	B	E	F
1	design	2.9	2.9	NA	NA	2.9	2.9	NA	NA
	actual	4.0	3.8			3.6	3.8		
2	design	2.9	2.9	NA	8.2	2.9	2.9	NA	8.2
	actual	4.0	3.5		10.2	4.0	3.3		9.8
3	design	2.9	2.9	NA	8.2	2.9	2.9	NA	8.2
	actual	3.3	3.3		10.7	3.5	3.6		10.1
4	design	4.3	4.3	NA	8.5	4.3	4.3	NA	8.5
	actual	3.5	3.6		10.1	3.8	3.6		9.6
5	design	4.2	4.2	NA	8.5	4.2	4.2	NA	8.5
	actual	3.5	3.5		11.8	3.7	3.5		9.3
6	design	4.2	4.2	NA	8.5	4.2	4.2	NA	8.5
	actual	3.6	3.6		12.6	3.6	3.7		11.4
7	design	4.2	4.2	NA	8.5	4.2	4.2	NA	8.5
	actual	3.5	3.4		9.2	3.4	3.5		9.5
8	design	4.2	4.4	NA	8.5	4.2	4.4	NA	8.5
	actual	3.9	4.0		8.4	3.5	3.8		7.6
9	design	4.4	4.4	NA	8.5	4.4	4.4	NA	8.5
	actual	3.8	4.5		11.0	5.3	5.3		11.0
inspection				qualified					
				unqualified					
result				only for reference					
Option									
redo				verify		customer		captain	
repair									
new part replacement									
trace									
as it stands									

IP Rotor Axial Clearance

Cabras Plant : Unit 2 . . .As Found Date : ..22/July/2017




unit : mm

		IP-LH				IP-RH			
		A	B	E	F	A	B	E	F
1	design	NA	8.58	6.25	NA	design	8.58	6.25	NA
	actual	NA	13.5	NA	NA	NA	13.8	NA	NA
2	design	3.61	9.14	3.73	8.51	3.61	9.14	3.73	8.51
	actual	5.1	11.3	NA	17.0	5.2	11.2	NA	15.4
3	design	4.09	3.83	3.96	8.81	4.09	3.83	3.96	8.81
	actual	7.1	12.9	NA	26.50	5.3	13.1	NA	26.4
4	design	4.04	9.73	4.16	9.12	4.04	9.73	4.16	9.12
	actual	7.3	13.7	NA	16.7	5.4	13.8	NA	16.6
5	design	4.27	10.21	4.52	9.35	4.27	10.21	4.52	9.35
	actual	6.6	13.9	NA	29.5	6.5	14.0	NA	29.3
6	design	4.42	10.84	4.67	9.60	4.42	10.84	4.67	9.60
	actual	6.3	13.9	NA	23.5	6.0	13.6	NA	23.6
7	design	4.52	11.05	4.93	9.80	4.52	11.05	4.93	9.80
	actual	6.4	15.2	NA	24.0	6.2	15.4	NA	24.0
8	design	4.65	11.46	5.16	10.01	4.65	11.46	5.16	10.01
	actual	6.3	12.5	NA	26.4	6.0	12.5	NA	26.1
9	design	4.63	11.15	5.14	10.13	4.63	11.15	5.14	10.13
	actual	6.2	14.2	NA	11.9	6.1	14.1	NA	11.8
inspection		qualified							
		unqualified							
result		only for reference							
Option									
	redo			verify		customer		captain	
	repair								
	new part replacement								
	trace								
	as it stands								

IP Rotor Axial Clearance

Cabras Plant : Unit 2 . .As Left Date : 02/Aug/2017.




unit : mm

		IP-LH				IP-RH			
		A	B	E	F	A	B	E	F
1	design		8.58	6.25	8.51	design	8.58	6.25	
	actual	7.9	12.4	12.1	16.5	7.2	11.9	9.2	15.5
2	design	3.61	9.14	3.73	8.51	3.61	9.14	3.73	8.51
	actual	4.9	11.5	14.1	25.5	4.7	11.5	13.9	26.5
3	design	4.09	3.83	3.96	8.81	4.09	3.83	3.96	8.81
	actual	4.8	12.5	13.5	16.7	4.7	12.5	13.3	26.5
4	design	4.04	9.73	4.16	9.12	4.04	9.73	4.16	9.12
	actual	5.2	13.6	12.4	29.6	5.2	13.5	12.2	29.6
5	design	4.27	10.21	4.52	9.35	4.27	10.21	4.52	9.35
	actual	5.5	13.7	12.3	23.4	5.8	13.8	12.8	23.9
6	design	4.42	10.84	4.67	9.60	4.42	10.84	4.67	9.60
	actual	5.8	13.7	13.5	24.0	5.8	13.5	12.6	23.7
7	design	4.52	11.05	4.93	9.80	4.52	11.05	4.93	9.80
	actual	6.2	15.2	13.6	26.0	6.3	15.2	13.7	26.0
8	design	4.65	11.46	5.16	10.01	4.65	11.46	5.16	10.01
	actual	6.5	12.5	13.6	12.1	6.5	12.4	13.4	12.7
9	design	4.63	11.15	NA	NA	4.63	11.15	NA	NA
	actual	6.6	13.9	NA	NA	6.5	13.8	NA	NA
inspection result		qualified							
		unqualified							
		only for reference							
Option									
	redo	verify			customer		captain		
	repair								
	new part replacement								
	trace								
	as it stands								
	repair								
	new part replacement								
	trace								
	as it stands								

LP Rotor Axial&Radial Clearance

Cabras Plant : Unit 2 . As found Date : 21/July/2017




Unit : mm

		LP-LH				LP-RH			
		A	B	E	F	A	B	E	F
TE4	design	12.5	18.5	NA	NA	12.5	18.5	NA	NA
	actual	1.2	19	NA	13	11.3	18.8	NA	12.5
TE3	design	13.3	18.5	NA	15.4	13.3	18.5	NA	15.4
	actual	9.8	18.3	NA	12.5	10	18.5	NA	12.5
TE2	design	13.3	18.5	NA	14.9	13.3	18.5	NA	14.9
	actual	10.5	21	NA	11.5	10.5	21.2	NA	11.5
TE1	design	11.32	16	NA	14.2	11.2	16.3	NA	14.2
	actual	11	NA	NA	NA	11.3	NA	NA	NA
GE1	design	9.9	9.9	NA	16.1	9.9	9.9	NA	16.1
	actual	9	NA	NA	NA	9	NA	NA	NA
GE2	design	11.8	13.5	NA	17.2	11.8	13.5	NA	17.2
	actual	9.5	19.2	NA	13.3	9.6	19.2	NA	13.3
GE3	design	11.6	12.3	NA	17.5	11.6	12.3	NA	17.5
	actual	7.7	16.6	NA	16.8	7.7	16.5	NA	16.8
GE4	design	11.6	16.8	NA	NA	11.6	16.8	NA	NA
	actual	8.6	18	NA	13.2	8.6	18.8	NA	13.2

inspection result		qualified		
		unqualified		
		only for reference		
Option				

LP Rotor Axial&Radial Clearance

Cabras Plant : Unit 2 . As Left Date : 02/Aug/2017.



Unit : mm

		LP-LH				LP-RH			
		A	B	E	F	A	B	E	F
TE4	design	12.5	18.5	NA	NA	12.5	18.5	NA	NA
	actual	11.6	17.3	NA	NA	11.9	17.9	NA	NA
TE3	design	13.3	18.5	NA	15.4	13.3	18.5	NA	15.4
	actual	10.0	14.8	NA	14.2	10.9	15.2	NA	12.6
TE2	design	13.3	18.5	NA	14.9	13.3	18.5	NA	14.9
	actual	11.1	14.2	NA	12.6	11.3	14.3	NA	12.6
TE1	design	11.32	16	NA	14.2	11.2	16.3	NA	14.2
	actual	11.3	13.2	NA	11.1	11.8	12.8	NA	11.2
GE1	design	9.9	9.9	NA	16.1	9.9	9.9	NA	16.1
	actual	8.3	9.5	NA	13.5	8.6	10.3	NA	11.5
GE2	design	11.8	13.5	NA	17.2	11.8	13.5	NA	17.2
	actual	8.8	14.2	NA	16.7	9.1	12.8	NA	16.2
GE3	design	11.6	12.3	NA	17.5	11.6	12.3	NA	17.5
	actual	7.6	12.4	NA	15.3	8.3	12.5	NA	14.4
GE4	design	11.6	16.8	NA	NA	11.6	16.8	NA	NA
	actual	8.5	15.7	NA	NA	8.8	14.4	NA	NA
inspection		qualified							
		unqualified							
result		only for reference							
Option									
	redo	verify		customer		captain			
	repair								
	new part replacement								
	trace								
	as it stands								

HP Packing ring clearance

Name	No.	AS FOUND				AS LEFT			
		L	B	R	T	L	B	R	T
HP Outer Gland	1	1.0	1.05	0.1	NA	1.0	0.77	0.1	1.5
	2	0.6	1.0	0.2	NA	0.8	0.88	0.2	1.6
HP Inner Gland	3	0.2	1.04	0.1	NA	0.1	1.04	0.3	1.5
	4	0.1	1.15	0.1	NA	0.1	1.02	0.3	1.5
HP TE Dummy	5	0.8	1.11	0.1	NA	0.1	1.02	0.6	2.22
	6	0.8	1.18	2.3	NA	0.1	0.98	0.8	1.86
	7	0.7	1.14	0.7	NA	0.1	0.96	0.1	2.11
HP	8	0.5	2.27	0.8	NA	0.7		0.7	2.33
	9	0.5	2.02	0.2	NA	0.2	1.52	0.7	1.04
	10	1.0	2.12	0.5	NA	0.5	1.73	0.6	1.78
	11	0.1	2.20	0.5	NA	0.5	1.52	0.7	1.56
	12	0.3	2.03	0.7	NA	0.6	1.35	0.6	1.33
	13	0.5	1.98	0.5	NA	0.8	1.09	0.9	1.60
	14	0.1	1.85	0.9	NA	0.5	1.51	0.8	1.68
	15	0.2	1.32	0.7	NA	0.18	1.32	0.9	1.63
HP Center Gland	16	0.7	1.23	1.0	NA	0.5	1.17	0.8	2.15
	17	0.2	1.23	1.0	NA	0.7	1.17	0.7	2.23
	18	0.2	1.23	0.8	NA	0.8	1.17	0.7	2.46
	19	0.1	1.18	1.0	NA	0.8	1.17	0.7	2.43
	20	0.3	1.15	0.8	NA	0.8	1.17	0.8	2.30

inspection result		qualified	verify	customer	captain
		unqualified			
		only for reference			
Treatment					
	redo				
	repair				
	new part replacement				
	trace				
	as it stands				

HP Seal Strip clearance

NO	AS FOUND				AS LEFT			
	L	B	R	T	L	B	R	T
1	1.5	2.27	1.2	NA	0.8	1.75	1.8	1.31
2	0.8	2.02	1.2	NA	0.8	2.10	1.0	1.92
3	1.0	2.12	0.7	NA	0.8	2.11	1.0	2.03
4	0.2	2.20	0.5	NA	1.0	2.27	1.0	1.72
5	0.8	2.03	0.7	NA	0.7	2.22	0.8	1.70
6	0.8	1.98	0.8	NA	1.0	2.19	0.8	1.73
7	1.0	1.85	0.9	NA	0.8	2.30	1.0	1.47
8	0.8	1.32	0.8	NA	0.7	2.26	1.2	1.08
9	0.8	1.32	0.8	NA	1.5	1.83	0.8	1.85

inspection result		qualified		
		unqualified		
		only for reference		
Treatment				
	redo	verify	customer	captain
	repair			
	new part replacement			
	trace			
	as it stands			

IP Packing ring clearance

Name	No.	AS FOUND				AS LEFT			
		L	B	R	T	L	B	R	T
IP TE Dummy	21	0.7	1.19	1.2	NA	0.6	1.17	1.0	2.33
	22	0.8	1.18	1.0	NA	0.7	1.17	1.0	2.41
	23	1.0	1.16	1.0	NA	0.9	1.17	1.0	2.37
IP	24	0.1	1.15	2.0	NA	0.9	NA	1.0	2.38
	25	0.5	1.15	2.0	NA	1.0	1.39	1.1	2.15
	26	0.5	1.43	1.3	NA	0.2	1.94	1.3	2.45
	27	0.1	2.31	1.5	NA	0.2	1.54	1.2	2.45
	28	0.1	2.25	1.1	NA	0.6	1.35	1.5	2.45
	29	0.1	2.0	1.3	NA	0.2	1.97	1.2	1.8
	30	0.1	2.25	0.7	NA	0.3	1.83	0.1	1.55
	31	0.5	2.2	1.5	NA	0.4	2.39	0.6	1.95
	32	0.5	2.2	1.5	NA	0.5	2.21	0.8	2.35
	33	0.1	1.8	1.5	NA	0.2	2.21	1.0	1.4
IP Inner Gland	34	0.2	0.8	1.0	NA	0.4	0.57	0.8	2.0
	35	0.3	1.03	0.9	NA	0.4	0.73	1.0	2.1
IP Outer Gland	36	0.2	1.04	0.8	NA	0.3	1.04	0.9	1.8
	37	0.3	1.6	1.1	NA	0.6	0.89	0.9	1.7

inspection result		qualified		
		unqualified		
		only for reference		
Treatment				
	redo	verify	customer	captain
	repair			
	new part replacement			
	trace			
	as it stands			

IP SEAL STRIP CLEARANCE

NO	AS FOUND				AS LEFT			
	L	B	R	T	L	B	R	T
1	2.0	1.1	1.8	NA	3.0	1.88	3.3	2.0
2	1.2	1.0	1.7	NA	0.9	1.85	3.0	2.2
3	0.5	1.6	2.1	NA	1.6	1.65	2.5	1.83
4	1.2	1.2	1.7	NA	1.0	2.11	2.8	2.15
5	1.3	1.6	2.0	NA	1.2	1.67	2.8	2.0
6	1.0	1.5	0.7	NA	1.1	1.68	1.9	2.0
7	1.3	1.4	1.4	NA	1.0	2.37	1.2	1.65
8	1.0	1.5	1.0-	NA	1.0	2.38	1.8	1.6
9	1.0	1.3	1.0	NA	1.0	2.02	1.8	1.7

inspection		qualified		
		unqualified		
	result	only for reference		
Treatment				
	redo	verify	customer	captain
	repair			
	new part replacement			
	trace			
	as it stands			

LP Packing ring clearance

Name	No.	AS FOUND				AS LEFT			
		L	B	R	T	L	B	R	T
LP TE Gland	38	0.05	1.03	0.8	NA	0.2	0.83	0.7	0.8
	39	0.25	1.15	0.35	NA	0.6	1.18	0.7	0.7
	40	0.30	0.98	0.35	NA	0.7	0.92	0.8	0.7
LP	41	0.4	1.4	1.0	NA	1.0	2.12	0.2	2.10
	42	0.4	1.53	0.8	NA	0.4	2.09	0.8	2.65
	43	0.7	1.7	0.8	NA	0.2	2.09	0.8	3.2
	44	0.15	1.45	1.0	NA	0.3	2.26	1.0	2.5
	45	0.8	1.7	0.7	NA	1.0	2.10	0.4	1.98
	46	0.2	1.53	1.4	NA	1.0	1.91	0.3	2.0
	47	0.5	1.35	0.5	NA	0.6	2.18	0.4	1.8
LP GE Gland	48	0.3	1.0	0.3	NA	0.4	0.82	0.2	0.8
	49	0.1	0.9	0.8	NA	0.3	1.05	0.3	0.6
	50	1.0	0.4	0.45	NA	0.2	1.03	0.2	0.7

inspection		qualified		
		unqualified		
	result		only for reference	
Treatment				
	redo	verify	customer	captain
	repair			
	new part replacement			
	trace			
	as it stands			


LP SEAL STRIP CLEARANCE

	AS FOUND				AS LEFT			
NO	L	B	R	T	L	B	R	T
22	1.6	1.46	2.0	NA	3.0	1.42	2.4	3.0
21	1.1	1.5	1.6	NA	1.5	1.43	1.5	1.5
20	1.1	1.82	1.4	NA	0.7	1.69	1.9	1.4
19	2.0	2.16	2.4	NA	1.0	2.28	2.5	3.1
19	1.9	3.07	2.5	NA	1.8	2.45	2.4	1.5
20	1.2	2.08	1.5	NA	1.5	2.01	1.1	1.0
21	1.7	1.99	2.5	NA	2.1	1.89	1.4	2.0
22	1.5	1.47	2.2	NA	2.0	1.45	2.3	3.0

inspection		qualified		
		unqualified		
	result	only for reference		
Treatment				
	redo	verify	customer	captain
	repair			
	new part replacement			
	trace			
	as it stands			

HP Outer Casing Joint Face Clearance

Cabras Plant : Unit 1 . . .As Found Date : 19/July/2017




TOOL NO :

unit : mm

inspection	qualified			
	unqualified			
	only for reference			
result				
Option				
	redo	verify	customer	captain
	repair			
	new part replacement			
	trace			
	as it stands			

HP Outer Casing Joint Face Clearance

Cabras Plant : Unit 1 . . .As left Date : 8/ August/2017




TOOL NO :

unit : mm

inspection		qualified		
		unqualified		
	result	only for reference		
Option				
	redo	verify	customer	captain
	repair			
	new part replacement			
	trace			
	as it stands			

Thrust Brg Clearance Check

Cabras Plant : Unit 1 . . .AsLeft ___Date : 02/Aug/2017



Thrust Brg Clearance Check


Unit : mm

		L	Casing L	Casing R	Gage	CLE	design
as found	rotor to TE	310.33		0	0	0.39	0.38
	rotor to GE	310.74		0.03	0.42		
as left	rotor to TE	9.79	0.02	0.01	0	0.39	0.50
	rotor to GE	10.22	-0.04	-0.02-	0.41		

inspection result		qualified	measureer	
		unqualified		
		only for reference		
Option				
	redo	verify	customer	captain
	repair			
	new part replacement			
	trace			
	as it stands			





OIL RING BORE Measurement

Cabras Plant : Unit 1 . . .As Found Date : 21/July/2017



CLEARANCE BETWEEN OIL RING BORE AND SHAFT


unit:mm



inspection		qualified		
		unqualified		
	result	only for reference		
Option				
	redo	verify	customer	captain
	repair			
	new part replacement			
	trace			
	as it stands			


OIL RING BORE Measurement

Cabras Plant : Unit 1 . . .As Left Date : 02/Aug/2017



CLEARANCE BETWEEN OIL RING BORE AND SHAFT


unit:mm



inspection		qualified		
		unqualified		
	result	only for reference		
Option				
	redo	verify	customer	captain
	repair			
	new part replacement			
	trace			
	as it stands			

RUNOUT CHECK

Cabras Plant : Unit 1 . .As Left -Date : 07/August/2010




UNIT : 1/100mm

	A	B	C	D	E	F
1	NA	NA	NA	19	22	NA
2	NA	NA	NA	20	23	NA
3	NA	NA	NA	23	22	NA
4	NA	NA	NA	22	22	NA
5	NA	NA	NA	22	22	NA
6	NA	NA	NA	22	23	NA
7	NA	NA	NA	22	22	NA
8	NA	NA	NA	20	21	NA

inspection		qualified		
		unqualified		
	result	only for reference		
Option				
	redo	verify	customer	captain
	repair			
	new part replacement			
	trace			
	as it stands			

Thrust Brg Parts Dimension Measurement

Cabras Plant : Unit 1. .As Left Date : 2/ Aug/2017



1.GAP	23.06
2.PLATE (TE)	18.90
3.SHIM (TE)	5.0
4.RUNNER	101.63
5.GAP	27.53
6.PLATE (GE)	19.00
7.SHIM (GE)	7.11
8.CASING	152.13

CLEARANCE CALACULATE :

$$\textcircled{8} - (\textcircled{2} + \textcircled{3} + \textcircled{4} + \textcircled{6} + \textcircled{7})$$

$$= 0.49$$

CLEARANCE

DESIGN : 0.015"~0.020"

inspection result		qualified		
		unqualified		
		only for reference		
Option				
	redo	verify	customer	captain
	repair			
	new part replacement			
	trace			
	as it stands			

HP INNER CASING BOLT STRETCH RH

Cabras Plant : Unit 1.. As Left Date : 04/Aug/2017

NO	BOLT SIZE	FREE LENTH	STRETCH	BEFORE STRETCH	AFTER STRETCH	FINAL STRETCH
1	2 ¹ / ₂ "	13"	0.41	13.92	13.49	0.43
2	2 ³ / ₄ "	13 ³ / ₄ "	0.36	2.81	2.43	0.38
3	3"	15"	0.43	6.85	6.40	0.45
4	3"	15"	0.43	6.97	6.51	0.46
5	4"	16"	0.46	6.83	6.35	0.48
6	4"	19"	0.56	8.69	8.12	0.57
7	4"	19"	0.56	8.16	7.56	0.60
8	4"	19"	0.56	8.52	7.93	0.59
9	4"	19"	0.56	8.98	8.41	0.58
10	4"	19"	0.56	5.94	5.37	0.57
11	3 ¹ / ₂ "	18"	0.54	4.94	4.37	0.57
12	3 ¹ / ₂ "	18"	0.54	8.74	8.20	0.54

inspection result		qualified		
		unqualified		
		only for reference		
Option				
	redo	verify	customer	captain
	repair			
	new part replacement			
	trace			
	as it stands			

HP INNER CASING BOLT STRETCH

LH

Cabras Plant : Unit 1. . As Left Date : 04/Aug/2017

NO	BOLT SIZE	FREE LENTH	STRETCH	BEFORE STRETCH	AFTER STRETCH	FINAL STRETCH
1	2 ¹ / ₂ "	13"	0.41	11.16	10.74	0.42
2	2 ³ / ₄ "	13 ³ / ₄ "	0.36	3.88	3.50	0.38
3	3"	15"	0.43	7.42	6.97	0.45
4	3"	15"	0.43	6.60	6.16	0.44
5	4"	16"	0.46	9.11	8.64	0.47
6	4"	19"	0.56	7.88	7.31	0.57
7	4"	19"	0.56	5.91	5.33	0.58
8	4"	19"	0.56	6.96	6.40	0.56
9	4"	19"	0.56	7.83	7.24	0.59
10	4"	19"	0.56	6.80	6.23	0.57
11	3 ¹ / ₂ "	18"	0.54	3.69	3.13	0.56
12	3 ¹ / ₂ "	18"	0.54	3.75	3.18	0.57

inspection result		qualified		
		unqualified		
		only for reference		
Option				
	redo	verify	customer	captain
	repair			
	new part replacement			
	trace			
	as it stands			

HP OUTER CASING BOLT STRETCH LH

Cabras Plant : Unit 1... As Left Date : 07/Aug/2017

NO	Bolt size	bolt lenth	stretch	Free lenth	After strecht	angle	final
1	3 ¹ / ₂ "	17"	48	12.95	12.47	NA	0.48
2	3 ¹ / ₂ "	17"	48	12.63	12.13	NA	0.50
3	3 ¹ / ₂ "	17"	48	12.86	12.35	NA	0.51
4	3 ¹ / ₂ "	18"	53	11.93	11.38	NA	0.55
5	3 ³ / ₄ "	18"	53	11.74	11.18	NA	0.56
6	4"	18 ¹ / ₂ "	48	12.67	11.16	NA	0.49
7	4 ¹ / ₂ "	18 ¹ / ₂ "	48	12.35	11.85	NA	0.50
8	4 ¹ / ₂ "	20 ¹ / ₂ "	56	22.03	21.43	NA	0.60
9	4 ¹ / ₂ "	20 ¹ / ₂ "	56	22.88	22.31	NA	0.57
10	4 ¹ / ₂ "	20 ¹ / ₂ "	56	21.43	20.83	NA	0.60
11	4 ¹ / ₂ "	20 ¹ / ₂ "	56	24.22	23.63	NA	0.59
12	4 ¹ / ₂ "	20 ¹ / ₂ "	56	19.92	19.34	NA	0.58
13	4 ¹ / ₂ "	20 ¹ / ₂ "	56	21.32	20.76	NA	0.56
14	4 ¹ / ₂ "	20 ¹ / ₂ "	56	24.41	23.83	NA	0.58
15	4 ¹ / ₂ "	20 ¹ / ₂ "	56	21.64	21.08	NA	0.56
16	4 ¹ / ₂ "	20 ¹ / ₂ "	56	23.73	23.13	NA	0.60
17	4 ¹ / ₂ "	20 ¹ / ₂ "	56	21.61	21.02	NA	0.59
18	4 ¹ / ₂ "	18 ¹ / ₂ "	48	24.81	24.31	NA	0.50
19	4 ¹ / ₂ "	18 ¹ / ₂ "	48	24.70	24.20	NA	0.50
20	4 ¹ / ₂ "	23"	48	23.60	23.11	NA	0.49
21	3 ¹ / ₂ "	17"	48	23.81	23.31	NA	0.50

inspection result		qualified		
		unqualified		
		only for reference		
Option				
	redo	verify	customer	captain
	repair			
	new part replacement			
	trace			
	as it stands			

HP OUTER CASING BOLT STRETCH RH

Cabras Plant : Unit : m/m As Left Date : 07/August/2017

NO	Bolt size	bolt lenth	stretch	Free lenth	After strecht	angle	final
1	3 ¹ / ₂ "	17"	48	13.04	12.54	NA	0.50
2	3 ¹ / ₂ "	17"	48	13.25	12.76	NA	0.49
3	3 ¹ / ₂ "	17"	48	13.17	12.67	NA	0.50
4	3 ¹ / ₂ "	18"	53	11.86	11.31	NA	0.55
5	3 ³ / ₄ "	18"	53	11.92	11.38	NA	0.54
6	4"	18 ¹ / ₂ "	48	11.45	10.97	NA	0.48
7	4 ¹ / ₂ "	18 ¹ / ₂ "	48	11.63	11.13	NA	0.50
8	4 ¹ / ₂ "	20 ¹ / ₂ "	56	24.20	23.62	NA	058
9	4 ¹ / ₂ "	20 ¹ / ₂ "	56	23.43	23.84	NA	0.59
10	4 ¹ / ₂ "	20 ¹ / ₂ "	56	22.99	22.39	NA	0.60
11	4 ¹ / ₂ "	20 ¹ / ₂ "	56	22.69	22.12	NA	0.57
12	4 ¹ / ₂ "	20 ¹ / ₂ "	56	22.53	21.94	NA	0.59
13	4 ¹ / ₂ "	20 ¹ / ₂ "	56	22.42	21.82	NA	0.60
14	4 ¹ / ₂ "	20 ¹ / ₂ "	56	21.70	21.12	NA	0.58
15	4 ¹ / ₂ "	20 ¹ / ₂ "	56	4.54	3.94	NA	0.60
16	4 ¹ / ₂ "	20 ¹ / ₂ "	56	22.57	22.16	NA	0.59
17	4 ¹ / ₂ "	20 ¹ / ₂ "	56	22.52	21.92	NA	0.60
18	4 ¹ / ₂ "	18 ¹ / ₂ "	48	23.70	23.20	NA	0.50
19	4 ¹ / ₂ "	18 ¹ / ₂ "	48	22.84	22.32	NA	0.52
20	4 ¹ / ₂ "	23"	48	24.05	23.56	NA	0.49
21	3 ¹ / ₂ "	17"	48	23.68	23.20	NA	0.48

inspection result		qualified		
		unqualified		
		only for reference		
Option				
	redo	verify	customer	captain
	repair			
	new part replacement			
	trace			
	as it stands			

HP STEAM INLET PIPE BOLT STRETCH

Cabras Plant : Unit 1. . As Left Date : 07/Aug/2017_

NO	BOLT SIZE	FREE LENTH	STRETCH	ANGLE	AFTER STRETCH	FINAL STRETCH
1	2 ¹ / ₂ "	19"	27	78°		7000NM
2	2 ¹ / ₂ "	19"	27	78°		7000NM
3	2 ¹ / ₂ "	19"	27	78°		7000NM
4	2 ¹ / ₂ "	19"	27	78°		7000NM
5	2 ¹ / ₂ "	19"	27	78°		7000NM
6	2 ¹ / ₂ "	19"	27	78°		7000NM
7	2 ¹ / ₂ "	19"	27	78°		7000NM
8	2 ¹ / ₂ "	19"	27	78°		7000NM
9	2 ¹ / ₂ "	19"	27	78°		7000NM
10	2 ¹ / ₂ "	19"	27	78°		7000NM
11	2 ¹ / ₂ "	19"	27	78°		7000NM
12	2 ¹ / ₂ "	19"	27	78°		7000NM

inspection result		qualified		
		unqualified		
		only for reference		
Option				
	redo	verify	customer	captain
	repair			
	new part replacement			
	trace			
	as it stands			

LP- GEN Coupling Bolt Stretching Measurement

Cabras Plant : Unit 1 .. As Left

Date : 9/ Aug/2017

一、TENSION VALUE

UNIT : mm

BOLT NO	FREE LENTH	FINAL LENTH	STRETCH	DESIGN
1	2.25	2.66	0.41	0.40 ∫ 0.43
2	2.29	2.69	0.40	
3	2.31	2.74	0.43	
4	2.16	2.56	0.40	
5	2.30	2.70	0.40	
6	2.15	2.56	0.41	
7	2.31	2.73	0.42	
8	2.24	2.64	0.40	
9	2.16	2.59	0.43	
10	2.17	2.57	0.40	
11	2.17	2.60	0.43	
12	2.21	2.61	0.40	



二、LP-GEN COUPLING Run-Out Check

	1	2	3	4	5	6	7	8	TIR	DESIGN
LP Coupling "A"	0.19	0.20	0.23	0.22	0.22	0.22	0.22	0.20	0.03	0.05mm
GEN Coupling "B"	0.22	0.23	0.22	0.22	0.22	0.23	0.22	0.21	0.01	0.05mm
A-B	0	0	0.02	0.03	0.03	0.03	0.03	0.02	0.03	0.04mm

inspection result		qualified		
		unqualified		
		only for reference		
Option				
	Redo	verify	customer	captain
	Repair			
	new part replacement			
	Trace			
	as it stands			

LP-GE Alignment


Cabras Plant : Unit 1 .As Left Date : 4/ August/2017



inspection result		qualified		
		unqualified		
		only for reference		
Option				
	redo	verify	customer	captain
	repair			
	new part replacement			
	trace			
	as it stands			

CV Stem Run Out Check

Cabras Plant : Unit 1. .As left Date : 31/July/2017



VALV NO.	A				B				C			
	0°	90°	180°	270°	0°	90°	180°	270°	0°	90°	180°	270°
1	0	3	5	2	0	-7	-12	-5	0	8	3	-5
2	0	0	0	0	0	0	0	0	0	0	0	0
3	0	2	3	1	0	-11	-11	0	0	0	0	0
4	0	-1	0	1	0	-8	-8	0	0	1	3	2
5	0	-2	-2	1	0	-11	-9	2	0	-2	1	3
6	0	-2	-1	-2	0	-14	-18	-4	0	-10	-12	-2

unit : 0.01mm


V/V NO	BUSHING ID	STEM OD	Clearance	DESIGN
1	38.14	37.85	0.29	0.20~0.254
2	38.15	37.88	0.27	0.20~0.254
3	38.17	37.94	0.23	0.20~0.254
4	38.04	37.83	0.21	0.20~0.254
5	38.10	37.88	0.22	0.20~0.254
6	38.08	37.80	0.28	0.20~0.254

unit : 0.01mm

inspection result		qualified		
		unqualified		
		only for reference		
Option				
	redo	verify	customer	captain
	repair			
	new part replacement			
	trace			
	as it stands			

IV Stem RUNOUT CHECK

Cabras Plant : Unit 1 . .As Left Date : 01/Aug/2017



unit : 1/100r

	A	B	C	D
1	NA	NA	NA	NA
2	NA	NA	NA	NA
3	NA	NA	NA	NA
4	NA	NA	NA	NA

二、Stem & Bushing Clearance Check


unit:mm

	a	c
Stem	59.90	59.91
Bushing	60.20	60.38
Clearance	0.30	0.47

inspection		qualified		
		unqualified		
	result	only for reference		
Option				
	redo	verify	customer	captain
	repair			
	new part replacement			
	trace			
	as it stands			

MSV Stem RUNOUT CHECK

Cabras Plant : Unit 1 . As Found Date : 25/July/2017



unit : 0.01mm

	A	B	C	D
1	0	0	0	0
2	3	-6	-1	31
3	3	-10	-2	42
4	0	-4	-1	11

二、Stem & Bushing Clearance Check


unit:0.01mm

	a	B
Stem	59.8	75.95
Bushing	60.02	76.18
Clearance	0.22	0.23

inspection result	<input type="checkbox"/>	qualified		
	<input type="checkbox"/>	unqualified		
	<input type="checkbox"/>	only for reference		
Option				
<input type="checkbox"/>	redo	verify	customer	captain
<input type="checkbox"/>	repair			
<input type="checkbox"/>	new part replacement			
<input type="checkbox"/>	trace			
<input type="checkbox"/>	as it stands			

RSV Stem RUNOUT CHECK

Cabras Plant : Unit 1 . As Found Date : 25/July/2017



unit : 0.01mm

	A	B	C	D
1	0	0	0	0
2	-8	2	0	0
3	-18	4	0	-2
4	-10	2	0	-2

二、Stem & Bushing Clearance Check

unit:0.01mm

	a	b
Stem	63.23	75.80
Bushing	63.60	76.10
Clearance	0.37	0.30

inspection result		qualified		
		unqualified		
		only for reference		
Option				
	redo	verify	customer	captain
	repair			
	new part replacement			
	trace			
	as it stands			

MSV BOLT STRETCH

Cabras Plant : Unit 1. .. As Left

Date : 08/August /2017

NO	BOLT SIZE	FREE LENTH	STRETCH	FIRST STRETCH	AFTER STRETCH	FINAL STRETCH
1	2 ³ / ₄ "	12 ³ / ₄ "	13	20.28	19.95	0.33
2	2 ³ / ₄ "	12 ³ / ₄ "	13	20.39	20.36	0.33
3	2 ³ / ₄ "	12 ³ / ₄ "	13	19.75	19.40	0.35
4	2 ³ / ₄ "	12 ³ / ₄ "	13	19.55	19.22	0.33
5	2 ³ / ₄ "	12 ³ / ₄ "	13	20.40	20.08	0.32
6	2 ³ / ₄ "	12 ³ / ₄ "	13	20.20	19.88	0.32
7	2 ³ / ₄ "	12 ³ / ₄ "	13	20.13	19.80	0.30
8	2 ³ / ₄ "	12 ³ / ₄ "	13	20.54	20.20	0.34
9	2 ³ / ₄ "	12 ³ / ₄ "	13	20.92	20.58	0.34
10	2 ³ / ₄ "	12 ³ / ₄ "	13	21.00	20.65	0.35
11	2 ³ / ₄ "	12 ³ / ₄ "	13	20.83	20.51	0.32
12	2 ³ / ₄ "	12 ³ / ₄ "	13	21.40	20.08	0.32
13	2 ³ / ₄ "	12 ³ / ₄ "	13	20.40	20.07	0.33
14	2 ³ / ₄ "	12 ³ / ₄ "	13	20.26	19.93	0.33
15	2 ³ / ₄ "	12 ³ / ₄ "	13	19.43	19.10	0.33
16	2 ³ / ₄ "	12 ³ / ₄ "	13	19.18	18.86	0.32
17	2 ³ / ₄ "	12 ³ / ₄ "	13	19.96	19.64	0.32
18	2 ³ / ₄ "	12 ³ / ₄ "	13	19.50	19.18	0.32

inspection result		qualified		
		unqualified		
		only for reference		
Option				
	redo	verify	customer	captain
	repair			
	new part replacement			
	trace			
	as it stands			

RSV BOLT STRETCH


Cabras Plant : Unit 1. .. As Left Date : 07/August /2017

NO	BOLT SIZE	FREE LENTH	STRETCH	ANGLE	AFTER STRETCH	FINAL STRETCH
1	2"	3300	NA			3300ft/lb
2	2"	3300	NA			3300ft/lb
3	2"	3300	NA			3300ft/lb
4	2"	3300	NA			3300ft/lb
5	2"	3300	NA			3300ft/lb
6	2"	3300	NA			3300ft/lb
7	2"	3300	NA			3300ft/lb
8	2"	3300	NA			3300ft/lb
9	2"	3300	NA			3300ft/lb
10	2"	3300	NA			3300ft/lb
11	2"	3300	NA			3300ft/lb
12	2"	3300	NA			3300ft/lb
13	2"	3300	NA			3300ft/lb
14	2"	3300	NA			3300ft/lb
15	2"	3300	NA			3300ft/lb
16	2"	3300	NA			3300ft/lb
17	2"	3300	NA			3300ft/lb
18	2"	3300	NA			3300ft/lb
19	2"	3300	NA			3300ft/lb
20	2"	3300	NA			3300ft/lb

inspection result		qualified		
		unqualified		
		only for reference		
Option				
	redo	verify	customer	captain
	repair			
	new part replacement			
	trace			
	as it stands			

ACP-1(1A) STEM RUN OUT CHECK

Cabras Plant : Unit1 As Found&Left Date : 08/August /2017



Unit : 1/100mm

	A	B	C	D	E
1	0	0	0	0	-1
2	-2.5	0	1	0	-1
3	-3	0	1	0	3
4	0	0	0	0	3

二、Stem & Bushing Clearance


Unit : mm

	a	b	C
Outside Dia	44.43	79.15	72.83
Inside Dia	44.58	79.61	73.38
Clearance	0.15	0.46	0.55

inspection result		qualified		
		unqualified		
		only for reference		
Option				
	redo	verify	customer	captain
	repair			
	new part replacement			
	trace			
	as it stands			

ACP-2(2A) STEM RUN OUT CHECK

Cabras Plant : Unit 1 As Found&Left Date : 08/August /2017



Unit : 1/100mm

	A	B	C	D	E
1	0	0	-1	0	0
2	2	0	-1	0	-2
3	1	0	-2	0	-1
4	-1	-1	-2	0	2

二、Stem & Bushing Clearance


Unit :mm

	a	b	C
Outside Dia	44.44	79.08	72.83
Inside Dia	44.61	79.57	73.34
Clearance	0.17	0.49	0.51

inspection result		qualified		
		unqualified		
		only for reference		
Option				
	redo	verify	customer	captain
	repair			
	new part replacement			
	trace			
	as it stands			

DCP-(EP) STEM RUN OUT CHECK

Cabras Plant : Unit 1 As Found&Left Date : 08/August/2017



Unit : 1/100mm

	A	B	C	D	E
1	0	0	-1	0	0
2	0	1	2	0	-4
3	-1.5	0	2	0	-4
4	-2	-1	1	0	-1

二、Stem & Bushing Clearance

Unit:mm

	a	B	C
Outside Dia	44.44	79.11	72.82
Inside Dia	44.60	79.44	73.36
Clearance	0.16	0.33	0.54

inspection result		qualified		
		unqualified		
		only for reference		
Option				
	redo	verify	customer	captain
	repair			
	new part replacement			
	trace			
	as it stands			

IV：建議事項

無